## **COMPRESSOR DATA SHEET**

**Rotary Compressor: Variable Frequency Drive** 

## MODEL DATA - FOR COMPRESSED AIR 1 Manufacturer: SULLIVAN PALATEK Model Number: **D-20 VFD** Date: 8/29/2019 2 Water-cooled **SCREW** Χ Air-cooled Type: Χ Oil-free Oil-injected # of Stages: <u>p</u>sig<sup>b</sup> Rated Operating Pressure 125 3 4 **Drive Motor Nominal Rating** 20 hp 5 **Drive Motor Nominal Efficiency** 93.6 percent 6 Fan Motor Nominal Rating (if applicable) NA hp 7 Fan Motor Nominal Efficiency NA percent Specific Power Capacity (acfm)<sup>a,d</sup> Input Power (kW) $(kW/100 acfm)^d$ 78.3 25.97 20.3 Max 69.1 18.1 26.26 8\* 62.2 16.4 26.37 54.7 14.8 27.15 47.3 13.3 28.09 38.8 30.64 11.9 Min Total Package Input Power at Zero Flow $^{c,\,d}$ 9\* 0.0 kW 35 30 25 20 10 15 10 100 Capacity (ACFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: <a href="https://www.cagi.org">www.cagi.org</a>

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

Member

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate			Specific Energy	No Load / Zero Flow
at specified conditions		Volume Flow Rate	Consumption	Power
m <sup>3</sup> / min	ft3 / min	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

OT 031

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.