## **COMPRESSOR DATA SHEET**

**Rotary Compressor: Variable Frequency Drive** 

		otary Compressor: MODEL DATA - I			
1	Manufacturer:	SULLIVAN	PALATEK		
	Model Number: <b>D4-25 VFD</b>			Date:	9/3/2019
2	X Air-cooled Water-cooled			Type:	SCREW
	X Oil-injected Oil-free			# of Stages:	1
3	Rated Operating Pressure			125	$psig^b$
4	Drive Motor Nominal Rating			25	hp
5	Drive Motor Nominal Efficiency			93.6	percent
6	Fan Motor Nominal Rating (if applicable)			NA	hp
7	Fan Motor No	minal Efficiency		NA	percent
	Input Power (kW)			city (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>
	23.2 Max			92.8	24.98
0.1	20.9			82.1	25.51
8*	18.9			72.9	25.93
	17.0			64.1	26.43
	15.1			54.9	27.47
	13.5 Min			46.4	29.03
9*	Total Package	otal Package Input Power at Zero Flow <sup>c, d</sup>		0.0	kW
10	Specific Power (kW/100 ACFM)	35 30 25 20			
		Note: Y-Axis Scale,	Capacity (ACFM only a visual representation to 10 to 35, + 5kW/100acfm in its Scale, 0 to 25% over may	on of the data in Section acrements if necessary ab	

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with

ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

Member

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

	ne Flow Rate fied conditions	Volume Flow Rate	Specific Energy  Consumption	No Load / Zero Flow Power
m <sup>3</sup> /min	ft3 / min	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.