## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

		MO	DEL DATA - FO	OR COMPRESSE	D AIR		
1	Manufacturer:	SULL	IVAN PALATEK				
	Model Number: D-20 VFD				Date:	08/29/19	
2	X Air-cooled Water-cooled				Type: Screw		
					# of Stages:	1	
3*	Full Load Operating Pressure b			125	psig		
4	Drive Motor Nominal Rating			20	hp		
5	Drive Motor Nominal Efficiency			93.6	percent		
6	Fan Motor Nominal Rating (if applicable)		N/A	hp			
7	Fan Motor No	minal Effici	ency	N/A	percent		
8*	Input Power (kW)			Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>		
	20.3			78	25.93		
	18.1			69	26.19		
	16.4			62	26.37		
	14.8			55	27.06		
	11.9			39	30.67		
9*	Total Package Input Power at Zero Flow c, d			0.0	kW		
10	Isentropic Effi	Isentropic Efficiency			%	Min. Value is too high	
11	Specific Power (KW/100 ACFM)	35.00					
		10.00	Note: Graph is only a vis	50 Capacity (ACFM) ual representation of the data in - 5kW/100acfm increments if nece to 25% over maximum capacity		100	

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
  b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
  c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.