## COMPRESSOR DATA SHEET

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

## **Rotary Compressor: Variable Frequency Drive**

		MO	DEL DATA - FO	OR COMPRESSE	D AIR			
1	Manufacturer	Manufacturer: SULLIVAN PALATEK						
	Model Numbe	er: <b>D4-2</b>	5 VFD		Date:	09/03/19		
2	X Air-cooled Water-cooled				Type:	Screw		
					# of Stages:	1		
3*	Full Load Ope	erating Press	sure	125	" of Buges.	psig <sup>b</sup>		
4	Drive Motor Nominal Rating			25	hp			
5	Drive Motor Nominal Efficiency			93.6	percent			
6	Fan Motor Nominal Rating (if applicable)			N/A	hp			
7	Fan Motor No	Fan Motor Nominal Efficiency			percent			
	Input Power (kW)			Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>			
	23.2	!		92	25.27			
8*	21.0	)		83	25.33			
	18.8	8		73	25.59			
	15.2			55	27.84			
	12.1		c, d	36		33.16		
9*	1		er at Zero Flow <sup>c, d</sup>	0.0	kW %			
10	Isentropic Eff	iciency		54.7%	%0			
11	Specific Power (kW/100 ACFM)	25.00						
	Specific (kW/100	20.00						
		15.00						
		10.00						
		0	25	50 75 Capacity (ACFM)	100	125		
	Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity							
For mod	els that are tested in	the CAGI De-	formance Varification D	rogram, these items are ve	rified by the th	ird party administrates		
			nts in the third party ver	-	www.cagi.org			
				npressor package in accorda	nce with ISO 12	17, Annex E;		
-	b. The opera	ting pressure a		8) and Electrical Consumpt				
is Institute			rdance with ISO 1217, An not significant" or "0" on	nex E, if measurement of no the test report.	load power equ	als less than 1%,		
	d. Tolerance	is specified in	ISO 1217, Annex E, as sh		document			
	NOIL. I	terms pow	e. and energy are synon					
	Volume Flow Rate at specified conditions Volume Flow R				NO LOAU /	,		
			Volume Flow Rate	Specific Energy Consumption	Zero Flow Power			
	at specified co		Volume Flow Rate %					

		ecified conditions	Volume Flow Rate	Consumption	Power
	$\underline{m^3 / min}$	ft <sup>3</sup> / min	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	
ROT 031.1	Above 15	Above 529.7	+/- 4	+/- 5	

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP, CAGI has not independently verified the reported data.