1	MODEL DATA - FOR COMPRESSED AIR Manufacturer: Sullivan Palatek, Inc.					
	Model Number: D-15	Date:	06/08/21			
2	X Air-cooled Water-cooled	Type:	Screw			
		# of Stages:	1			
3*	Rated Capacity at Full Load Operating Pressure ^{a, e}	50.1	acfm ^{a,e}			
4*	Full Load Operating Pressure ^b	125	psig ^b			
5	Maximum Full Flow Operating Pressure ^c	125	psig ^c			
6	Drive Motor Nominal Rating	15	hp			
7	Drive Motor Nominal Efficiency	92.4				
8	Fan Motor Nominal Rating (if applicable)	N/A	hp			
9	Fan Motor Nominal Efficiency	N/A	percent			
10*	Total Package Input Power at Zero Flow ^e	4.70	kW ^e			
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	12.31	kW^d			
12*	Package Specific Power at Rated Capacity and Full Load Operating Pressure ^e	24.58	kW/100 cfm ^e			
13	Isentropic Efficiency	61.12	Percent			
	els that are tested in the CAGI Performance Verification Program, these items are ve CAGI website for a list of participants in the third party verification program: <u>v</u>	rified by the third party ad www.cagi.org	ministrator.			
NOTES	 a. Measured at the discharge terminal point of the compressor package in accordar ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions. b. The operating pressure at which the Capacity (Item 3) and Electrical Consumpti for this data sheet. c. Maximum pressure attainable at full flow, usually the unload pressure setting for maximum pressure attainable before capacity control begins. May require addit d. Total package input power at other than reported operating points will vary with 	on (Item 11) were measured r load/no load control or the ional power.				

compresses and dos institute	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
Member	m^3 / min	ft^3 / min	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%
ROT 030.1	Above 15	Above 529.7	+/- 4	+/- 5	
ROT 030.1	Above 15	Above 529.7	+/- 4	+/- 5	

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.