COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR									
1	Manufacturer: Sullivan Palatek								
	Model Number: SP13-H40VFD				Date:	01/26/23			
2	Air-cooled Water-cooled				Type:	Screw			
					# of Stages:	1			
3*	Full Load Oper	Full Load Operating Pressure b			psig ^b				
4	Drive Motor N	ominal Rating		40	hp				
5	Drive Motor N	ominal Efficiency		93.0	percent				
6	Fan Motor No	an Motor Nominal Rating (if applicable)		1	hp				
7	Fan Motor No	an Motor Nominal Efficiency		85.5	percent				
8*	Input Power (kW)			Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	34.8			147.7	23.57				
	28.7			118.3	24.30				
	25.6			103.1	24.79				
	19.8			73.8	26.77				
	16.8		0.4	58.9 28.58		28.58			
9*	Total Package	Total Package Input Power at Zero Flow c, d			kW				
10	Isentropic Effi	ciency		65.4%	%				
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00 15.00 10.00 0.0 25.0 50. Note: Gr Note: Y-Axis	Cap raph is only a visual Scale, 10 to 35, + 51	0.0 125.0 150.0 175. pacity (ACFM) Il representation of the data in kW/100acfm increments if neces	Section 8	0 250.0 275.0			

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.