COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer:	Sullivan Palatek						
	Model Number	:: SP13-HH60VFD		Date:	09/06/23			
2	X Air-co	ooled Water-cooled		Type:	Screw			
				# of Stages:	1			
3*	Full Load Operating Pressure		175	psig b				
4	Drive Motor N	Drive Motor Nominal Rating		hp				
5	Drive Motor Nominal Efficiency		95.4	percent				
6	Fan Motor Nor	Fan Motor Nominal Rating (if applicable)		hp				
7	Fan Motor No	minal Efficiency	86.5	percent Specific Power				
	Input Power	r (kW)	Capacity (acfm) ^{a,d}	(kW/100 acfm) ^d				
	56.0		215.4	25.99				
8*	44.4		172.0		25.78			
	39.0		150.4	25.94				
	29.2		107.4	27.19				
	24.8		85.9	28.86				
9*	Total Package Input Power at Zero Flow c, d		0.0	kW				
10	Isentropic Effi	ciency	67.3%	%				
11	Specific Power (RW/100 ACFM)	Note: Y-Axis Scale, 10 to	100.0 125.0 150.0 175 Capacity (ACFM) a visual representation of the data in 35, + 5kW100acfm increments if nece	Section 8	0 250.0 275.0			

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{\mathbf{m}^3 / \mathbf{min}}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.