## **COMPRESSOR DATA SHEET**

## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Fixed Speed**

MODEL DATA - FOR COMPRESSED AIR 1 Manufacturer: **Sullivan Palatek** SPM-5 Model Number: Date: 2/12/2024 2 Air-cooled Water-cooled Type: Screw # of Stages: 1 Rated Capacity at Full Load Operating Pressure a, e acfm<sup>a,e</sup> 18.1  $\underline{psig}^b$ Full Load Operating Pressure 4\* 125 Maximum Full Flow Operating Pressure c psig<sup>c</sup> 125 5 Drive Motor Nominal Rating 6 5.0 hp Drive Motor Nominal Efficiency 7 89.5 percent Fan Motor Nominal Rating (if applicable) 8 0.2 hp Fan Motor Nominal Efficiency 75.0 percent Total Package Input Power at Zero Flow<sup>e</sup>  $kW^{e}$ 10\* 1.8 Total Package Input Power at Rated Capacity and Full Load 11  $kW^d$ Operating Pressure<sup>d</sup> 5.1 Package Specific Power at Rated Capacity and Full Load Operating 12\* 28.38 kW/100 cfm<sup>e</sup> Pressure 13 Isentropic Efficiency 52.93 Percent

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m³/min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	+/- 10%
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

Member

ROT 030.1

12/19 Rev This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org