## **COMPRESSOR DATA SHEET**

## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Fixed Speed** 

MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: Sullivan Palatek					
	Model Number: SPM-H7.5 1 PH	Date:	11/27/2024			
2	X Air-cooled Water-cooled	Type:	Screw			
	X Oil-injected Oil-free	# of Stages:	1			
	Rated Capacity at Full Load Operating Pressure					
3*	a, e	23.1	acfm <sup>a,e</sup>			
4	Full Load Operating Pressure b	150	psig b			
5	Maximum Full Flow Operating Pressure c	150	psig <sup>c</sup>			
6	Drive Motor Nominal Rating	7.5	hp			
7	Drive Motor Nominal Efficiency	84	percent			
8	Fan Motor Nominal Rating (if applicable)	0.2	hp			
9	Fan Motor Nominal Efficiency	75.0	percent			
10*	Total Package Input Power at Zero Flow	2.3	kW <sup>e</sup>			
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	7.0	$kW^d$			
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure	30.32	kW/100 cfm <sup>e</sup>			

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.

e. Tolerance is specified in ISO 1217, Annex C, as shown in table below: NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Member

ROT 030.2

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> /min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org