## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

		MO	DEL DA	TA - F(	OR COMI	PRESSE	D AIR		
1	Manufacturer:	Sulliv	an Palatel	k					
	Model Number			Date:	(	03/07/25			
2	X Air-cooled Water-cooled				Т		Type:		Screw
							# of Stages:		1
3*	Full Load Operating Pressure b				10	)0	psig		
4	Drive Motor Nominal Rating			12	25	hp			
5	Drive Motor Nominal Efficiency			95	.8	percent			
6	Fan Motor Nominal Rating (if applicable)			2.	0	hp			
7	Fan Motor Nominal Efficiency				88	.5	percent		
	Input Power (kW)				Capacity	(acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>		
	114.8			648		17.70		,	
8*	90.9			513	3.2	17.54			
	79.6				453	3.8	17.54		
	58.0				324	4.1	17.90		
	47.5			259	9.5	18.30			
9*	Total Package Input Power at Zero Flow c, d			0.	0	kW		kW	
10	Isentropic Efficiency			74.	3%	%			
11	Specific Power (kW/100 A.CFM)	25.00							_
	ads	15.00	Note: Y-Axis Sc	oh is only a vis	300.0 Capacity (ACFM, sual representatio - 5kW100acfm in 0 to 25% over max	n of the data in crements if nece		600.0	700.0

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
  b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
  c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.